

# Confirmation

## BREEAM<sup>®</sup> NOR 2016

On 3 November 2016, Eurofins Product Testing A/S received a sample of flooring with the product name:

**Zero**

supplied by

**Upofloor Oy**


The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000-3 -6 -9 -11 and CEN/TS 16516 in the latest versions (See test report no. 392-2016-00406201\_A\_EN).

**The test results of the tested flooring indicate that the product qualifies for BREEAM-NOR New Construction 2016 v1.0 specifications on VOC emissions complying with:**

**BREEAM NOR 2016 requirements on "Volatile Organic Compounds" in Hea 02 criteria for resilient textile and laminated floor coverings according to EN 14041:2004**

- TVOC was below the limit of 200  $\mu\text{g}/(\text{m}^2\cdot\text{h})$  after 28 days
- Formaldehyde was below the limit of 50  $\mu\text{g}/(\text{m}^2\cdot\text{h})$  after 28 days
- Carcinogenic substances was below the limit of 5  $\mu\text{g}/(\text{m}^2\cdot\text{h})$  after 28 days

15 December 2016

  
\_\_\_\_\_  
Janne R. Norup  
Chemist

  
\_\_\_\_\_  
Maria Pelle  
Chemist