Test No: 146821



PO Box 1948 - 1503 East Morris Street - Dalton, GA 30722

Phone: 706-278-3013

Fax: 706-272-7057 .

E-mail: info@ittslab.com

Test Report

Customer: UPOFLOOR

August 25, 2014

Subject: One sample of vinyl floor covering submitted by the customer and identified as below.

Sample Identification: Upofloor Zero 5703

Contract Sheet

Date of Manufacturing: 25th June 2014

Test Method Conducted ASTM F 137 Standard Test Method for Flexibility of Resilient Flooring Materials with Cylindrical Mandrel Apparatus

Scope:

This method covers the determination of the flexibility of resilient flooring materials by means of cylindrical mandrel apparatus. It is especially applicable to sheet goods and some tiles.

Specified Mandrel: 1 1/2"

TEST RESULTS	-
Cracking	None
Crazing	None
Sample rating	Passes

President L. Kent Suddeth

Our letters and reports are for the exclusive use of the customer to whom they are addressed, and their communication to any others or the use of the name of independent Textile Testing Service, inc., must receive out prior written approved. Our letters and reports apply only to the sample tested and are not necessarily indicative of the qualities of apparently identical or similar products. The reports and letters and the name of independent Textile Testing Service, inc., are not to be used under any circumstances in advertising to the general public.